



NOTES:

1. HAND TAMP SOIL UNDER AND AROUND THE ENTRANCE SECTION IN LIFTS NOT TO EXCEED 6 INCHES.
2. ENSURE THAT ALL SLOPE DRAIN CONNECTIONS ARE WATERTIGHT.
3. DIVERSION DIKES RIDGES MUST BE AT LEAST ONE FOOT MINIMUM ABOVE THE TOP OF THE PIPE.
4. CONSTRUCT INLET TO SLOPE DRAIN OF STANDARD FLARED-END SECTION OF PIPE WITH A MINIMUM 6 INCH METAL TOE PLATE. A STANDARD T-SECTION FITTING MAY ALSO BE USED AT THE INLET.
5. DRAINAGE FILL PER SPECIFICATIONS.

TEMPORARY SLOPE DRAIN DETAIL

NO SCALE

MAX DRAINAGE AREA:
1 ACRE

TD