



1. INSTALLATION SHALL COMPLY WITH ASTM D 6462 LATEST EDITION.
2. GEOTEXTILE TO BE FASTENED SECURELY TO STAKES.
3. WHEN TWO SECTIONS OF GEOTEXTILE ADJOIN EACH OTHER THEY SHALL BE OVERLAPPED BY 18 to 60 INCHES AS SHOWN.
4. MAINTENANCE SHALL BE PERFORMED AS NOTED IN THE SWPPP. COLLECTED MATERIAL SHALL BE REMOVED WHEN "BULGES" DEVELOP IN THE SEDIMENT FENCE.

SILT FENCE WITHOUT WIRE SUPPORT DETAIL

NO SCALE